

**Current Transformer  
Model 682**  
*Window Diameter 7.62"*

REGULATORY AGENCY APPROVALS



Manufactured to meet the requirements of ANSI/IEEE C57.13.  
Classified by U.L. in accordance with IEC 44-1



**APPLICATION:**

Relying and Metering.

**FREQUENCY:**

50-400 Hz.

**INSULATION LEVEL:**

0.6 kV, BIL 10 kV full wave.

**CONTINUOUS THERMAL**

**CURRENT RATING FACTOR:**

50:5 thru 2000:5: 2.0 at 30°C. amb., 1.5 at 55°C. amb.

2500:5 thru 3500:5: 1.33 at 30°C. amb., 1.0 at 55°C. amb.

4000:5: 1.0 at 30°C. amb., 0.75 at 55°C. amb.

Secondary terminals are brass screws No. 10-32 with one flatwasher and lockwasher.

Multi-ratios available on request.  
Consult Factory.

Approximate weight 30 lbs.

CATALOG NUMBER	CURRENT RATIO	RELAY CLASS	ANSI METERING CLASS AT 60HZ					SECONDARY WINDING RESISTANCE (OHMS @ 75°C)
			BO.1	BO.2	BO.5	BO.9	B1.8	
682-500	50:5	C5	4.8	—	—	—	—	0.014
682-750	75:5	C10	2.4	4.8	—	—	—	0.020
682-101	100:5	C10	2.4	4.8	—	—	—	0.027
682-151	150:5*	C20	0.6	1.2	2.4	—	—	0.044
682-201	200:5*	C25	0.6	1.2	2.4	—	—	0.071
682-251	250:5*	C35	0.6	0.6	1.2	2.4	—	0.089
682-301	300:5*	C40	0.6	0.6	1.2	1.2	2.4	0.106
682-351	350:5*	C55	0.3	0.6	0.6	1.2	2.4	0.124
682-401	400:5*	C60	0.3	0.6	0.6	1.2	1.2	0.142
682-501	500:5*	C75	0.3	0.3	0.3	0.6	1.2	0.177
682-601	600:5*	C100	0.3	0.3	0.3	0.6	1.2	0.212
682-751	750:5*	C100	0.3	0.3	0.3	0.6	0.6	0.266
682-801	800:5*	C130	0.3	0.3	0.3	0.6	0.6	0.283
682-102	1000:5*	C170	0.3	0.3	0.3	0.3	0.3	0.354
682-122	1200:5*	C200	0.3	0.3	0.3	0.3	0.3	0.425
682-152	1500:5*	C200	0.3	0.3	0.3	0.3	0.3	0.531
682-162	1600:5*	C200	0.3	0.3	0.3	0.3	0.3	0.567
682-202	2000:5*	C210	0.3	0.3	0.3	0.3	0.3	0.648
682-252	2500:5*	C300	0.3	0.3	0.3	0.3	0.3	0.810
682-302	3000:5*	C300	0.3	0.3	0.3	0.3	0.3	0.938
682-352	3500:5*	C300	0.3	0.3	0.3	0.3	0.3	1.371
682-402	4000:5*	C300	0.3	0.3	0.3	0.3	0.3	1.962

Approved for revenue metering by Industry Canada No. AE-0646(\*)

# Model 682

